

Exhibit KeySpan 2

January 5, 2006

Mr. William R. Maher, P.E.
Senior Project Engineer
Judith Nitsch Engineering, INC.
186 Lincoln Street Suite 200
Boston, MA 02111

Subject: Proposed Construction of a 31 Story Mixed use Building and Underground
Parking Garage
Boston

Dear Mr. Maher:

Please be aware that Keyspan maintains an 8 inch cast-iron main in Province Street, and a 6 inch cast-iron main in Chapman Place located 3 feet off your proposed construction. Any construction within three feet of our facilities by code will require our mains to be re-laid.

KeySpan Energy Delivery will have no objections to this project receiving Public Improvement Commission approval, if the owners of Abbey Province LLC agree to pay for all cost associated with the relocation of our existing 8 inch and 6 inch mains within the project area.

Please keep me informed regarding the status of this project, and if you require further information please call me at (781) 466-5249.

Sincerely,

Winston Watson
Senior Engineer
Utility Engineering

KED file number 06-4816